



Certificate of Compliance

FIRE PROTECTION EQUIPMENT

This certificate is issued for the following equipment: **See pg 2**

System Description – Model Designations

Approval Guide Listing: Category:

- Fuel & Combustion Controls Pressure Supervisory Switches Pressure Supervisory Switches for Fuel Gas and Ventilating or Combustion Air

Dwyer Instruments Inc
102 Indiana Hwy 212
Mercoïd Div
PO Box 373
Michigan City
IN
46361-0373
United States

This certifies that the equipment described has been found to comply with the applicable requirements, as stated in the Approval Report(s), of the following FM Approval Standards and other documents:

<i>Approval Standards</i>	<i>Date</i>	<i>Other Standards</i>	<i>Date</i>
<i>Class Number</i>		<i>Organization, Designation</i>	
3510	January 2000		

Original Approval Job Identification: 3040704 Approval Granted: 1990

Related Report: 0M4A5AF

Subsequent Revisions:

To verify the availability of the Approved product, please refer to www.approvalguide.com



J.E. Marquedant
Manager of Electrical Systems
FM Approvals
1151 Boston-Providence Turnpike,
Norwood MA, 02062 USA

Date 9 February 2017



Member of the FM Global Group



Certificate of Compliance

Model 1950G

Model 1950G-00(or 0, 02,5, 10, 20)-B(or F, N, S, V)-120(or 240)-NA (or Blank). Operating ranges 0.07 to 0.15, 0.15 to 0.5, 0.4 to 1.6, 1.4 to 5.5, 3.0 to 11.0, and 4.0 to 20.0 in. H₂O (0.2 mbar up to 50 mbar). Rated operating pressure 45 in. H₂O (120 mbar). Operates at 120 or 240 V ac. Contacts rated at 10 A. FM Approved for use in Class I, Division 1, Groups B, C, D; dust-ignitionproof for Class II, Division 1, Groups E, F and G hazardous (classified) locations; and indoor/outdoor (NEMA Type 3) environments.



Member of the FM Global Group