



11

EC - DECLARATION OF CONFORMITY

We, Dwyer Instruments, Inc.
P.O. Box 373
Michigan City, IN 46361, USA
(219) 879-8868

declare under our sole responsibility that our Series DCGII Digital Pressure Gauge to which this declaration relates are in conformity with the following EC Directives and harmonized standards:

Directive 2004/108/EC (EMC)

EN 61326-1 (2006) Electrical Equipment for Measurement, Control, and Laboratory Use - EMC Requirements - Part 1: General Requirements

EN 61000-4-2 (2001) Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

EN 61000-4-3 (2002) Electromagnetic Compatibility (EMC) - Part 4-3 Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

CISPR11 (2003) Industrial, Scientific and Medical (ISM) Radio-Frequency Equipment-Electromagnetic Disturbance Characteristics-Limits and Methods of Measurement

The authorized representative located within the Community is:

Dwyer Instruments Ltd
Unit 16, The Wye Estate, London Road
High Wycombe, Bucks HP11 1LH-U.K.
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, Inc.

Michigan City, Indiana, USA
7/15/11

Senior Regulatory Engineer